



Municiple Council Tuljapur

Tal. Tuljapur Dist-Dharashiv

E-mail.-tuljapurmc@gmail.com



O.No.MCT/2024 /15

Date-4/4/2024

To,

Principle

Shri Tuljabhavani Sainiki Vidyalay,

Tuljapur. Tal - Tuljapur. Dist - Dharashiv. - 413601

Sub - Fire and safety certificate

Ref - Letter Of LOGITECH FIRE TECHNOLOGY Dt. 03/04/2024

With above refernce it is Certified that the Shri Tuljabhavani Sainiki Vidyalay, Tuljapur. Tal-Tuljapur Dist- Dharashiv. - 413601, comprised of ground + First floor which occupied by Shri Tuljabhavani Sainiki Vidyalay, Tuljapur. Tq.-Tuljapur Dist.-Dharashiv 413601 have complete with the fire prevention and fire safety requirements in accordance with rule of state/UT fire services rules and verified by the officer concerned of fire service on 04/04/2024 in the presence Shri Pramod Bhojane the building/premises is fit for Occupancy class 6th to 12th With effect from 04/04/2024 for the period of one year.


Issued on 04/04/2024 fire department Of Municipal Council of Tuljapur Tal. Tuljapur Dist. Dharashiv.

Singnature :-

Name :-

Signature of Shri. 
प्रमाणितकारी
श्री. प्रमोद भोजने
तुळजापूर


PRINCIPAL
Shri Tuljabhavani Sainiki Secondary
and Higher Secondary Vidyalaya
Tuljapur Dist. Dharashiv


MANAGER (ADMIN)
Shree Tuljabhavani Temple Trust
Tuljapur Dist. Dharashiv



LOGITECH FIRE TECHNOLOGY

An ISO 9001:2015 Certified Company

Authorized Govt. License Agency for Maharashtra Fire Services, Mumbai.

Email: logitechfire101@gmail.com | www.logitechfire.com Contact: 020 2952 4549 /

9764600101/9373682113



Date: 3rd April, 2024

Ref: LFT/01/2024

CERTIFICATE

Party Name: Shri Tuljabhavani sainik Sec. Higher Sec School, Tuljapur Jil. Dharashiv Pin Code : 413601

Sr. No.	Description	Unit	QTY
1	ABC Type refilling 6 kg Capacity Fire Extinguisher	Nos	8
2	CO2 Type 4.5 Kg Capacity Fire Extinguisher	Nos	4
3	Horn CO2 4.5/6.5/9 Kg Capacity Fire Extinguisher	Nos	1
4	ABC Type 1kg Capacity Fire Extinguisher	Nos	1
5	ABC Type 6kg Capacity Fire Extinguisher	Nos	8

B.I.S SPECIFICATION: ISI 15683:2006

HYDRO TEST: TESTED TO 22KG/CM2

WARRENTY:

The above-mentioned goods are warranted against defect in material & workmanship under normal use the warranty is limited to a period of **twelve months** from the refilling date to limited to rectifying repairing & replace defective parts ex-factory, provided the purchase has given immediate written notice upon the discovery of such defect. The company will be automatically relieved of its prior approved within the guaranteed period the warranty accident resulting the defective and faulty workmanship.



Logitech Fire Technology

PRINCIPAL

**Shri Tuljabhavani Sainik Secondary
and Higher Secondary Vidyalaya
Tuljapur Dist. Dharashiv**

MANAGER (ADMIN)

**Shree Tuljabhavani Temple Trust
Tuljapur Dist. Dharashiv**

Regd Office: Flat C-101, Shreya Garden, Danga Park, Near Navale Bridge, Vadgaon Bk, Pune



LOGITECH FIRE TECHNOLOGY

An ISO 9001:2015 Certified Company

Authorized Govt. License Agency for Maharashtra Fire Services, Mumbai.

Email: logitechfire101@gmail.com | www.logitechfire.com Contact: 020-2952 4549 /

9764600101/9373682113



Date: 3rd April, 2024

Ref: LFT/01/2024

CERTIFICATE

Party Name: Shri Tuljabhavani sainik Sec. Higher Sec School, Tuljapur Jil. Dharashiv Pin Code : 413601

Sr. No.	Description	Unit	QTY
1	ABC Type refilling 6 kg Capacity Fire Extinguisher	Nos	8
2	CO2 Type 4.5 Kg Capacity Fire Extinguisher	Nos	4
3	Horn CO2 4.5/6.5/9 Kg Capacity Fire Extinguisher	Nos	1
4	ABC Type 1kg Capacity Fire Extinguisher	Nos	1
5	ABC Type 6kg Capacity Fire Extinguisher	Nos	8

B.I.S SPECIFICATION: ISI 15683:2006

HYDRO TEST: TESTED TO 22KG/CM2

WARRENTY:

The above-mentioned goods are warranted against defect in material & workmanship under normal use the warranty is limited to a period of **twelve months** from the refilling date to limited to rectifying repairing & replace defective parts ex-factory, provided the purchase has given immediate written notice upon the discovery of such defect. The company will be automatically relieved of its prior approved within the guaranteed period the warranty accident resulting the defective and faulty workmanship.



Logitech Fire Technology

[Signature]

PRINCIPAL

**Shri Tuljabhavani Sainik Secondary
and Higher Secondary Vidyalaya
Tuljapur Dist. Dharashiv**

[Signature]

MANAGER (ADMIN)

**Shree Tuljabhavani Temple Trust
Tuljapur Dist. Dharashiv**

Regd Office: Flat C-101, Shreya Garden, Dangat Park, Near Navale Bridge, Vadgaon(Bk), Pune.